

OCP Ready COLO Facility Assessment	N01 Campus			
Self Assessment Status:	COMPLETE-MEETS REQUIREMENTS			
Data Center Location Name	N01 Campus (DCM122)			
Data Center Location Address	N01 Campus, Stølevangen 39, Vennesla - Norway			
Site Description: White Space Area	1300sqm Built			
Site Description: Critical IT Power	4MW IT load infrastructure, 25MVA Site Infrastructure installed, 132kV & 110kV supplies for 100MVA			
Site Description: Network Provider Availability	TELA, TELENOR, Altibox, Blix, Global connect, Tampnet, TDC,Electricity link			
Site Description: Facility Features	Campus layout with two x security houses and Carrier Meet me rooms. Separate DC buildings with first building constructed			
Site Description: Other Services	Colocation, Build to suit, powered land on remaining 3sqkm land			
Date Original Assessment is Completed	12th March 2021			
Re-Assessment Date:				
REQUIREMENTS - Attribute (Must have an Optimum or Acceptable result)	Parameter	Result		Notes
ACCESS				
Building Access	1. Loading dock with lift or leveler	Optimum		
Delivery pathway, Loading dock to Goods In	1. ≥2.7m (108in) H x ≥2.4m (96in) W x ≥2.4m (96in) D unobstructed access and threshold free	Optimum		
Delivery pathway, Goods in to White space	2. ≥2.3m (90in) H x ≥.9m (36in) W with thresholds (notes required)	Acceptable		Goods lifter into white space
Corridor floor rolling load	1. ≥680kg (1500lb) (6.67kN)	Optimum		Solid floor
Unboxing/pre-staging/storage area floor uniform load	1. ≥1221kg/m2 (250lb/ft2) (11.97kN/m2)	Optimum		
Unboxing/pre-staging/storage area floor concentrated load	1. ≥680kg (1500lb) (6.67kN)	Optimum		
RAMPS				
Gradient	1. Not Applicable - No Ramps Required	Optimum		
Width	1. Not Applicable - No Ramps Required	Optimum		
Landing area	1. Not Applicable - No Ramps Required	Optimum		
Railings	1. Not Applicable - No Railings Required	Optimum		
LIFTS / ELEVATORS				
Weight loading	2. ≥500kg (1250lbs)	Acceptable		DC on Ground floor. Lift for first floor personnel only
Door height	1. Not Applicable - No Lift/Elevator Required	Optimum		
Width	1. Not Applicable - No Lift/Elevator Required	Optimum		
Depth	1. Not Applicable - No Lift/Elevator Required	Optimum		
WHITE SPACE				
Floor rolling load	1. ≥680kg (1500lb) (6.67kN)	Optimum		
Floor uniform load	1. ≥1221kg/m2 (250lb/ft2) (11.97kN/m2)	Optimum		
Floor concentrated load	1. ≥680kg (1500lb) (6.67kN)	Optimum		
Finished floor to ceiling height	1. ≥4.5m (180in)	Optimum		
Access floor clearance	1. ≥900mm (36in) (if used for cooling)	Optimum		
ELECTRICAL				
Number of independent circuits to the rack	1. 2N (A+B)	Optimum		A+B
Maximum circuit capacity	1. ≥ 32A/230V	Optimum		400V TNS -> 3x 230V/32A
Circuit voltage	1. 400/230 VAC nominal	Optimum		
Circuit frequency	1. 47-63 Hz	Optimum		50Hz
Power receptacle / WIP Type	1. IEC60309 532R6W	Optimum		
Circuit receptacle location	1. Overhead	Optimum		Tap Off Box on Busbar
Upstream UPS options	2. UPS only feed available	Acceptable		
Rack-based batteries permitted	2. Not Allowed (Notes Required)	Acceptable		In a dedicated customer room then yes
Generator load acceptance time	1. <60 seconds	Optimum		
COOLING				
Rack airflow direction	1. Front to Back	Optimum		
Air containment methods	1. Hot aisle containment or rack chimney	Optimum		We have three DC Halls. Hall one is hot aisle containment with underfloor supply and ceiling void return to IEC Hall two is Hot Aisle Containment using inrow coolers Hall three is a combination of Hot aisle containment using inrow units and Rear Door heat exchangers
Maximum rack density	1. ≥12kw	Optimum		Mixed Hall 1 - 10kW Hall 2 & 3 above 12kW (MAX 60kW)
Minimum cold aisle width	2. ≥1200mm (48in)	Acceptable		
Minimum free width cold aisle (Inside cage)	1. ≥1200mm (48in)	Optimum		
Minimum hot aisle width	1. ≥1200mm (48in)	Optimum		
Inlet air conditions	1. ASHRAE Class A1 Allowable	Optimum		
Air quality	1. EN 779 G4 and F7 filtering & Gas particulate monitoring to the ANSI/ISA 74.04-1985 G severity levels	Optimum		
Temperature rise	1. ≥12 Deg C DeltaT	Optimum		
Cabinet blanking of open space	1. Mandatory	Optimum		Demand for maximum 3% air leakage outside 19" area
CABLING				
Cabling infrastructure pathways	1. Top and Front of rack fed	Optimum		
Overhead Network Infrastructure containment levels	2. 2 Levels (Intra-Pod cabling; Inter-Pod cabling)	Acceptable		Option for further dedicated cable raceways possible in dedicated areas
Fibre Type (if installed)	1. OS2 & OM4	Optimum		
Fibre connection presentation (if installed)	1. Interchangeable LC Duplex and MPO	Optimum		High density fibre solution >=72pairs per U as standard
CONSIDERATIONS (For information only)	Parameter	Result		Notes
SERVICE				
Replacement PSU Modules	2. Secure storage available	Acceptable		Replacement units/critical spares can be maintained on further agreement
Replacement BBU Modules	2. Secure storage available	Acceptable		Replacement units/critical spares can be maintained on further agreement
Option to monitor PSUs and BBUs	2. No	Acceptable		Service management available through partners
Remote hands for PSU and BBU replacement or expansion	1. Yes	Optimum		Onsite Remote/Smart hands services available
Remote hands for OCP IT hardware replacement or expansion	1. Yes	Optimum		Onsite Remote/Smart hands services available
EFFICIENCY				
Site Operations Standards	2. Other (Notes required)	Acceptable		EN50600-3.1 Operators certified according to CDCTP level
Site PUE Monitoring	1. Continuously monitored	Optimum		Data collection in high resolution captured on influx database
Site Design PUE	1. <1.2	Optimum		Design PuE @ 1.2
Site Annualized PUE Current Achievement	2. Other (Notes required)	Acceptable		
Site WUE Monitoring	2. Other (Notes required)	Acceptable		Currently not Monitored, but implementation is under consideration for datahall 1 currently utilizing IEC cooling approach
Site CUE Monitoring	2. Other (Notes required)	Acceptable		Not Monitored, but to be implemented
OPENNESS				
PUE Published	2. Available upon request	Acceptable		
Facility Design Drawings & Files	2. Available to view upon request	Acceptable		

Oslo Internet Exchange OS-IX			
COMPLETE-MEETS REQUIREMENTS			
OS-IX			
Hans Møller Gasmanns vei 9			
8600sqm			
8MVA available			
Multiple Carriers 60+ (list available upon request)			
3 story building with separate energy center. Onsite offices and storage.			
12th March 2021			
Parameter	Result		Notes
1. Loading dock with lift or leveler	Optimum		Loading bay consisting of loading dock. Accessible by truck or van. Access for 5eml Trailer not possible. Trucks that are not able to deliver directly to dock level needs to be equipped with tail lift for ground delivery before goods can be transported in
1. ≥2.7m (108in) H x ≥2.4m (96in) W x ≥2.4m (96in) D unobstructed access and threshold free	Optimum		Loading dock Length = 8150 mm Width = 3800mm Height from ground = 1150mm Height from dock to covered area ceiling = 3500mm Door opening width from dock = 2400mm Door opening height from dock = 2500mm
2. ≥2.3m (90in) H x ≥.9m (36in) W with thresholds (notes required)	Acceptable		Max 120cm corridors in certain areas. Threshold on one door for one zoned area, with mini ramp Up to 1500 kg/m² dependant on area within the location
1. ≥680kg (1500lb) (6.67kN)	Optimum		1500kg/m2
1. ≥1221kg/m2 (250lb/ft2) (11.97kN/m2)	Optimum		750kg
1. ≥680kg (1500lb) (6.67kN)	Optimum		
2. 1:12 - 1:8	Acceptable		No Ramp option available for High Power Rack density areas , racks directly on slab ( build to suit)
2. ≥1.3m (48in)	Acceptable		
1. ≥1.5m x 1.5m (60in x 60in)	Optimum		
1. ≥900mm (36in) and <1000mm (40in)	Optimum		
1. ≥1500kg (3300lbs)	Optimum		5000kg load capacity
1. ≥2.4m (96in) Lift /Elevator door opening height (not internal cabin)	Optimum		2,6M
1. ≥1.5m (60in) Unobstructed door opening width	Optimum		2,4M
1. ≥1.5m (60in) Unobstructed cabin depth	Optimum		Lift (inside measurements): Length = 3850 mm Width = 1700mm Height = 2990mm
1. ≥680kg (1500lb) (6.67kN)	Optimum		750kg
1. ≥1221kg/m2 (250lb/ft2) (11.97kN/m2)	Optimum		1500kg/m2
1. ≥680kg (1500lb) (6.67kN)	Optimum		750kg
2. ≥3.1m (124in)	Acceptable		3,3M at lowest points due to cross beams
1. ≥450mm (18in) (if not used for cooling)	Optimum		600mm
1. 2N (A+B)	Optimum		A+B
1. ≥ 32A/230V	Optimum		400V TNS -> 3x 230V/32A
1. 400/230 VAC nominal	Optimum		
1. 47-63 Hz	Optimum		50Hz
1. IEC60309 532R6W	Optimum		
1. Overhead	Optimum		Tap Off Box on Busbar
2. UPS only feed available	Acceptable		
2. Not Allowed (Notes Required)	Acceptable		In client dedicated hall then yes
1. <60 seconds	Optimum		
1. Front to Back	Optimum		
2. Hot/Cold aisle containment for all cabinets in white space	Acceptable		Multiple halls can be designed to accommodate client specific requirements
2. ≥8kw	Acceptable		Option for dedicated higher density areas
2. ≥1200mm (48in)	Acceptable		Option for customer requirement available
1. ≥1200mm (48in)	Optimum		
1. ≥1200mm (48in)	Optimum		
1. ASHRAE Class A1 Allowable	Optimum		
1. EN 779 G4 and F7 filtering & Gas particulate monitoring to the ANSI/ISA 74.04-1985 G severity levels	Optimum		
1. ≥12 Deg C DeltaT	Optimum		
1. Mandatory	Optimum		Demand for maximum 3% air leakage outside 19" area
2. Top and Rear of rack fed	Acceptable		Top and Front feeding possible in dedicated areas
2. 2 Levels (Intra-Pod cabling; Inter-Pod cabling)	Acceptable		Option for further dedicated cable raceways possible in dedicated areas
1. OS2 & OM4	Optimum		
1. Interchangeable LC Duplex and MPO	Optimum		High density fibre solution >=72pairs per U as standard
Parameter			
2. Secure storage available	Acceptable		Replacement units/critical spares can be maintained on further agreement
2. Secure storage available	Acceptable		Replacement units/critical spares can be held on further agreement
2. No	Acceptable		Service management available through partners
1. Yes	Optimum		Onsite Remote/Smart hands services available
1. Yes	Optimum		Onsite Remote/Smart hands services available
2. Other (Notes required)	Acceptable		EN50600-3.1 Operators certified according to CDCTP level
1. Continuously monitored	Optimum		Data collection in high resolution captured on influx database
2. <1.5	Acceptable		Design PuE @ 1.3
2. <1.5	Acceptable		1.27 in 2020
2. Other (Notes required)	Acceptable		Not Monitored
2. Other (Notes required)	Acceptable		Not Monitored, but to be implemented
2. Available upon request	Acceptable		
2. Available to view upon request	Acceptable		

DK01 Campus			
COMPLETE-MEETS REQUIREMENTS			
DK01			
Guldborgsundvej 14, 6705 Esbjerg, Denmark			
512 sqm Built- Modular design 1MW modules			
1 MW IT load infrastructure, 3,5MVA Site Infrastructure installed			
TDC, GlobalConnect, Tampnet			
12th March 2021			
Parameter	Result		Notes
1. Loading dock with lift or leveler	Optimum		
1. ≥2.7m (108in) H x ≥2.4m (96in) W x ≥2.4m (96in) D unobstructed access and threshold free	Optimum		
2. ≥2.3m (90in) H x ≥.9m (36in) W unobstructed access and threshold free	Acceptable		
1. ≥680kg (1500lb) (6.67kN)	Optimum		
1. ≥1221kg/m2 (250lb/ft2)(11.97kN/m2)	Optimum		Floor type IV 1260 Jack load 23kN (safety factor 1,35) Divided load 18 kN/m2 default load.
1. ≥680kg (1500lb) (6.67kN)	Optimum		
1. Not Applicable - No Ramps Required	Optimum		
1. Not Applicable - No Ramps Required	Optimum		
1. Not Applicable - No Ramps Required	Optimum		
1. Not Applicable - No Railings Required	Optimum		
1. ≥1500kg (3300lbs)	Optimum		
1. Not Applicable - No Lift/Elevator Required	Optimum		
1. ≥1.5m (60in) Unobstructed door opening width	Optimum		
1. ≥1.5m (60in) Unobstructed cabin depth	Optimum		
1. ≥680kg (1500lb) (6.67kN)	Optimum		
1. ≥1221kg/m2 (250lb/ft2)(11.97kN/m2)	Optimum		
1. ≥680kg (1500lb) (6.67kN)	Optimum		
2. ≥3.1m (124in)	Acceptable		
1. ≥900mm (36in) (if used for cooling)	Optimum		
1. 2N (A+B)	Optimum		A+B
1. ≥ 32A/230V	Optimum		400V TNS -> 3x 230V/32A
1. 400/230 VAC nominal	Optimum		
1. 47-63 Hz	Optimum		50Hz
1. IEC60309 532R6W	Optimum		
2. Underfloor	Acceptable		Tap Off Box on Busbar
2. UPS only feed available	Acceptable		
2. Not Allowed (Notes Required)	Acceptable		Batteries are normally not permitted due to operating conditions in the WS. Some battery types requires ventilation and may be at risk in a common colocation environment. (In a shared colocation area batteries are not allowed, but in a dedicated client room they are)
1. <60 seconds	Optimum		
1. Front to Back	Optimum		
2. Hot/Cold aisle containment for all cabinets in white space	Acceptable		Cold aisle containment as standard. Underfloor supply and room return
1. ≥12kw	Optimum		
2. ≥1200mm (48in)	Acceptable		
1. ≥1200mm (48in)	Optimum		
1. ≥1200mm (48in)	Optimum		
1. ASHRAE Class A1 Allowable	Optimum		
1. EN 779 G4 and F7 filtering & Gas particulate monitoring to the ANSI/ISA 74.04-1985 G severity levels	Optimum		
1. ≥12 Deg C DeltaT	Optimum		
1. Mandatory	Optimum		Demand for maximum 3% air leakage outside 19" area
2. Top and Rear of rack fed	Acceptable		Top and Front feeding possible in dedicated areas
2. 2 Levels (Intra-Pod cabling; Inter-Pod cabling)	Acceptable		Option for further dedicated cable raceways possible in dedicated areas
1. OS2 & OM4	Optimum		
1. Interchangeable LC Duplex and MPO	Optimum		High density fibre solution >=72pairs per U as standard
Parameter			
2. Secure storage available	Acceptable		Replacement units/critical spares can be maintained on further agreement
2. Secure storage available	Acceptable		Replacement units/critical spares can be maintained on further agreement
2. No	Acceptable		Service management available through partners
1. Yes	Optimum		Onsite Remote/Smart hands services available
1. Yes	Optimum		Onsite Remote/Smart hands services available
3. Other (Notes required)	Acceptable		EN50600-3.1. Operators certified according to CDCTP level
2. Other (Notes required)	Acceptable		Data collection in high resolution captured on influx database
1. <1.2	Optimum		Design PuE @ 1.2
2. <1.5	Acceptable		Current measurement at 1,36
2. Other (Notes required)	Acceptable		Not Monitored
2. Other (Notes required)	Acceptable		Not Monitored
2. Available upon request	Acceptable		
2. Available to view upon request	Acceptable		